

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM  
**LISTING SERVICE**



**LISTING No.** 7120-1615:187

Page 1 of 1

**CATEGORY:** Annunciators

**LISTEE:** Bosch Security Systems, 130 Perinton Parkway, Fairport, NY 14450  
Contact: Frank Mioduszewski (585) 678-3368 FAX (585) 678-3263

**DESIGN:** Models \*D9069B (passive) and \*D9070B (active) remote annunciators. \*The D9069B (passive) annunciators will only show the operation of the FACP. \*The D9070B (active) annunciators will show the operational state of the FACP and can also control the FACP using the FIRE DRILL, ALARM SILENCE, TROUBLE SILENCE and RESET functions. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** Input 21.5 – 25.5 VDC, 125 mA, Supervised  
\*Note: D9070B may/may not be supervised depending on address setting.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as remote annunciators for use with separately listed fire alarm control units, Model D10024A (CSFM Listing 7165-1615:186). Refer to listee's Installation Instructions Manual for details.

**FORMERLY:** 7120-0801:219

**XL:** 7120-1596:101

\*Rev 03-17-2006 jw



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 29, 2008**

*Listing Expires **June 30, 2009***

Authorized By: **BEN HO, Chief**  
*Fire Engineering Division*